



NOTES:

1. ALL CONCRETE TO BE 3000 PSI AND FINISHED WITH CURING COMPOUND.
2. SEE STANDARD DETAIL "T-0.00" FOR THROUGH DRIVEWAY SPECIFICATION.
3. EXPANSION JOINTS TO BE A MAXIMUM OF 50 FEET.
4. CONTROL JOINT EVERY 5 FEET.
5. ALL SIDEWALKS SHALL BE CONSTRUCTED WITH TOOLED 1/4" EDGE RADIUS.
6. IF UTILITY STRIP IS COMPLETELY ELIMINATED SIDEWALK SHALL BE PLACED DIRECTLY AT BACK OF CURB, WITH 1/4" EDGE RADIUS.

" NOT TO SCALE "



DATE: 02/2017

TOWN OF CHAPEL HILL
STANDARD DETAIL

REVISIONS

TYPICAL
SIDEWALK

T-8.01